



GOULDEN
HOUSE
CO-OPERATIVE

Estate Office
Entrance A
Bullen Street
Battersea
London SW11 3HF

T 020 7924 5213
F 020 7924 5441
E office@gouldenhouse.org

NOTICE TO RESIDENTS – Lift H116 (BLOCK C) – UPDATE FROM WANDSWORTH BOROUGH COUNCIL TODAY (8TH JUNE 2026)

My colleague Graham has been liaising with Amalgamated Lifts on the status of the lift shutdown. The lift was shut down due a timed intermediate defect found by the insurance inspection – The counterweight operating clearance exceeds the installers maximum operating clearance as detailed on the counterweight screen and this should be rectified before the 05/07/2026 (one month).

Please use Lifts H114 (LIFT A) & H115 (LIFT B), until such time Lift H116 (Block C), is placed back in service.

We apologise in advance for any inconvenience caused, however, the circumstances are beyond our control.

For and on behalf of Goulden House Co-Operative Ltd

Annie Gleeson MSc
Estate Manager